



Faster Installation

Rail-less Pre-assembled



Reduced Cost

Less Parts Injection moulded



Advanced Material

Glass-reinforced composite
UV-stabilized
Corrosion resistant



Innovative Design

Self-sealing Auto-alignment with roof profile Fits all panel dimensions



Greener


Made from 100% recyclable material

TABLE OF CONTENTS

	INTRODUCTION	`
1	1.1 Tools Required	
	1.2 General Rules of Safety	
	1.3 General Guidelines	
	INSTALLATION	
2	2.1 Components	
	2.2 Installation Preparation	
	2.3 Bracket Placement	
	2.4 Secure Bracket to Sheeting	
	2.5 Secure Panel In Place	
\bigvee	2.6 End Spacer Installation	
	2.7 Install Earth Plate	
	2.8 Anti-tamper Cap Installation	
	TECHNICAL	
3	Data Sheet	
	General Arrangement	

INTRODUCTION

1.1 TOOLS REQUIRED



INTRODUCTION


1.2 GENERAL RULES OF SAFETY

- Only qualified and appropriately trained installers are authorized to install and operate the equipment.
- Before installing, verify that the product adheres to on-site static loading requirements. In the case of roofmounted systems, it is imperative to consistently assess the roof's loadbearing capacity.
- Adherence to health and safety regulations, accident prevention guidelines, and relevant standards is mandatory.
 - Wear protective gear, including a safety helmet, boots, and gloves.
 - Roofing activities should align with roofing regulations, employing fall protection measures when eaves height exceeds 3 m.
 - Ensure the presence of a minimum of two individuals throughout the installation process to promptly respond to emergencies
- All installation and assembly instructions provided by the panel manufacturer must be adhered to

- Performing equipotential bonding, grounding, or earthing among individual parts should align with country-specific standards, as well as adhere to national laws and regulations.
- A copy of the installation instructions should always be available during installation.
- Failure to follow Deo Solar's general safety and assembly instructions and utilize all system components releases the company from liability for any resulting defects or damages. Deo Solar does not assume responsibility for any damage incurred through the use of parts from competitors, and warranty coverage is excluded in such instances.
- Adhering to all safety instructions and ensuring the correct installation of the system qualifies for a 10-year product warranty entitlement. We highly recommend reviewing our guarantee terms, accessible at deosolar.co.za. Upon request, we can also provide this information.
- The system is dismantled in the reverse order of its assembly.

INTRODUCTION





Roof Requirements

- Trapezoidal sheet metal thickness
 - Aluminium ≥ 0.5 mm (with a tensile strength of 165 N/mm²)
 - o Steel ≥ 0,4 mm (S235 acc. DIN EN 10025-1)
- Roof pitch inclination: 5 45°
- Integrity of roof sheets and substrate to be verified by as required by National and Local regulations before placement of panels or brackets




Mounting Instructions

- Earthing in accordance with panel manufacturer instructions as well as National and Local regulations should be adhered to at all times.
- Always perform visual inspection of roof sheeting to ensure that the integrity is not compromised where a bracket are to be secured.
- Deo Solar brackets are not compatible with frameless modules. Ensure that module specifications are compatible with Deo Solar brackets before securing brackets on roof sheeting.
- Ensure that bracket placement is correctly calculated in accordance with solar module dimensions before mounting to roof sheeting.
- Ensure that clamps at the ends of panels are flush to the panel frame before tightening.

2.1 COMPONENTS



2.1 COMPONENTS (CONTINUED)



2.1

COMPONENTS (CONTINUED)

#	Component	Description	Material
А		Tamper Proof Cap	HDPE
В		M8 x 65	304 Stainless Steel
С		Top Bracket	Industrial Composite
D		M5 x 25 Taper Shaft Stitching Screw	Class 4 Zinc plated
Е		Sealing Washer	Rubber
F		Base Bracket (IBR)	Industrial Composite
G		DS T-Nut holder	Industrial Composite
Н		M8 Nut	GR8.8 zinc plated



INSTALLATION PREPARATION



Solar array design

- Complete solar array layout design
- Determine location of brackets based on panel specific requirements
- Tabulate bracket coordinates for site installation



Verify layout


- Verify available roof space against solar array design
- Determine placement location of first bracket (reference location)
- Mark reference location on roof




Mark installation locations

- Using the reference location, mark the installation location of each bracket as per the tabulated coordinates.
- Verify that layout is correct as per design before proceeding with installation of the solar brackets.
- Deo Solar will not be held liable for incorrect placement of brackets on roof plates

2.3 BRACKET PLACEMENT




2.4 SECURE BRACKET TO SHEETING






Secure bracket in place with a stitching screw complete with sealing washer on each side of the bracket.


Do not Strip. Avoid over torque during installation.



2.5 SECURE PANEL IN PLACE




- 14-20Nm
 - 1. Place Panel.
 - 2. Slide top bracket onto solar panel frame.
 - 3. Secure panel in place once correctly placed on supporting ends of the bottom bracket.
 - 4. Do not over torque components.



2.6


END SPACER INSTALLATION

Place end spacer on the top of the bracket in accordance with relevant panel thickness (30mm or 35mm or 40mm). Once in position, secure in accordance with torque setting in section 2.6.





30 mm Panel Thickness






35 mm Panel Thickness






40 mm Panel Thickness






2.7 INSTALL EARTH PLATE

Assemble earth clip on the top bracket as shown before installation of solar panels in order to bond panel frames.






2.8

ANTI-TAMPER CAP INSTALLATION

Once top brackets are firmly secured proceed with installation of antitamper cap



Place anti-tamper cap in position on the top cap as shown.

Ensure correct alignment on all sides upon placement.



TECHNICAL DATA

3.1 DATASHEET



Technical Data

Material	PA-6 UV with glass fibre	Yield Strength	145 Mpa	
	reinforcement	Modulus of Elasticity	9,5 Gpa	
	reilliorcement	Temperature of deflection under load	210 deg Celcius	
	Top Bracket			
Components	Bottom Bracket			
	Anti-tamper cap			
	t-nut			
	M8 x 60/65 Bolt			
	Taper Shaft Stitching Screws			
		IBR profile sheet, minimum thickness of 0,5r	nm. Roof cobering	
Uplift	Roof Structure	should be fixed to the substrate adequately to comply with building		
		regulations		
	Maximum Design Wind Uplift	3,2 kPa		
	Safety Factor In Design	1,2		



Auto-alignment



Self sealing design

TECHNICAL DATA

3.2

GENERAL ARRANGEMENT

